



- NOTES:**
1. HYDRANTS SHALL MEET THE REQUIREMENTS IN THE SPECIAL PROVISIONS.
 2. HYDRANTS PROVIDED BY WTDS.
 3. USE EBAA MEGALUGS OR APPROVED EQUIVALENT ON ALL JOINTS OF HYDRANT BRANCH.
 4. SEE WATR-3000 FOR MANHOLE REQUIREMENTS.
 5. LEAK SEAL AROUND SPACE.

STANDARD MANHOLE COVER DETAIL

	DRW: JAS	DATE: 2/22/16	HYDRANT BRANCH MANHOLE	STANDARD PLATE NO. WATR-1002
	APP: JQP	DATE: 2/22/16		

NOT TO SCALE